



Chhatrapati Sambhajanagar. Municipal Corporation

FIRE BRIGADE

TELEPHONE NO-2334000-40FAX No-2331444

Outward No:CSMC/FIRE 1490/2026

Date 21/ 03 /2026

To,
Principal, Shri. Rahul Mohanpurkar,
S.B.E.S Centenary School,
S.B. Camus. Opp, Axis bank,
Nirala Baza road, Chhatrapati Sambhajanagar.

Sub;- Revise Provisional Fire Noc is issued to the Principal, Shri. Rahul Mohanpurkar, S.B.E.S Centenary School, S.B. Camus. Opp, Axis bank, Nirala Baza road, Chhatrapati Sambhajanagar.

Ref:- 1) Your Letter date 02/02/2023
3) Your Letter date 19/03/2026

2)Provisional Noc on date 06/02/2023
4) CFO Inspectio on date 19/03/2026

With Reference to the above subject Revise Provisional Fire Noc is issued to the Principal, Shri. Rahul Mohanpurkar, S.B.E.S Centenary School, S.B. Camus. Opp, Axis bank, Nirala Baza road, Chhatrapati Sambhajanagar. Plot area is 35498.40 Sq.mtr.

Owner has paid Fire Fund Rs.00 /- & Provisional Fire Noc fees Rs. 10,000/- in Fire Brigade in Receipt No. 13590 on date 19 /03 /2026.

S.No	Building	Height	Building	Floor	Area of Plot	Builtup Area	Fire Fund	Noc Fees
1	S.B.E.S Centenary School,	11.40 Mtr	01	B+G+2	35498.40 Sq.mtr	641.89Sq.mtr	00	10000
							00	10000


Following Fire prevention and Fire protection & Fire Fighting measures subject to S.B.E.S Centenary School, shall be provided.

1. Open space around the building shall be provided for the movement of fire tender and which will carry 25 tons. weight capacity of suitable Capacity for building shall be Provided.
2. Overhead water tank 20000 Ltr, Main Fire Pump-900 LPM-01 No. of suitable Capacity for Building Shall be Provided.
3. Fire service inlet 2 way incoming shall be provided.
4. Hydrant points all around the building with fire Hose Pipe/ Branch shall be provided.
5. Down Commer having outlet on all floors with Hose Pipe / Branch shall be Provided.
6. Hose reel of 100 feet on all outlets shall be provided.
7. Fire Extinguisher of / ABC / Co2 of suitable Capacity / quantity shall be provided.
8. Automatic / Munally Sprinkler System, Automatic / Munally Smoke Detector System, Alarm System Manual Call Point, Hooter shall be Provided.
9. Main staircase 2.00 mtr & Fire Escape staircase 1.50 Mtr shall be Provided.
10. This Certificate shall be treated valid for a period of one year from, the date of issue up to Final Fire Noc

The Fire Fighting System arregament installed for proposed area such as hydrant system, Hose reel, fire extinguisher to the proposaed construction.

Sr.No.	Fire Fighting Installation	Requirements	Provision	Remarks
1	Prtable Fire Extinguishers	Requird	IS. 15683 & Is. 2190	Portable fire Etinguisher should be installed confirming to IS 15683 & Other I.S Codes
2	Hose Reel	Required Prominent Places	At Varous Strategic Locations	On each floor in the staircase landing for fire fighting thr first and hose reel shall be connected directly to rise r/Down Commer Main and diameter of the hose reel shall not be less than 19 mm Confirming to IS 884. 1985.
3	Booster pump	Pump shall be provided	All the fire Pumps must be centrifugal pumps only.	
4	Fire brigade connection	Required at the Main gate and on fire water tank	For Static water tank and for Hydrant system.	

As per BPMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006 Reference to above subject Revise **Provisional Fire Noc is issued to the Principal, Shri. Rahul Mohanpurkar, S.B.E.S Centenary School, S.B. Camus. Opp, Axis bank, Nirala Baza road, Chhatrapati Sambhajinagar.**


 Chief Fire Officer 20/03/26
 Fire Brigade, Municipal Corporation
 Chhatrapati Sambhajinagar.

Copy to:- C S T.P, Chhatrapati Sanbhajinagar